

July 25, 2019

## **QUESTIONS AND ANSWERS**

### **SET # 6**

**TO** : All Prospective Bidders

**FROM** : Ehab Azab, Contracts Administrator

**SUBJECT** : Set #6 - Contract C19010 – Cerone Division Emergency Generator Replacement

---

Q24. I have the following questions about the two existing generators; I am trying to see if these generators can be used elsewhere, IE: Schools, Hospitals etc.

- (a) Who are the Manufactures of the two existing generators?
- (b) How many hours are on each generator?
- (c) What are the outputs of the two generators? (Kilowatts)
- (d) Is the existing ATS still in working order?
- (e) Is the existing generator control panel still in working order?
- (f) Can I get a picture of the name plates on the existing generators?
- (g) Do the two existing exhaust louvre systems function properly?

A24. **Section 02 80 00 Hazardous Materials Removals, Part 3.08 "Generator and Boiler Closure Work"** of the Technical Specifications set forth in Bid Documents Volume 2 contains language specific to the generator removals.

Also, please refer to **Appendix N Regulatory Permit Applications** of the Bid Documents Volume 1 for information regarding regulatory guidelines pertaining to the re-use of aboveground hazardous materials storage tanks. VTA makes no representation as to whether these generators can be used elsewhere.

(a) Generators are propane fueled Caterpillar G399 Kato generators.

Generator #1:

Caterpillar G399 Serial Number: 49C00643

Kato Serial Number: 80578

Kato Catalogue Code: 6P61438

Kato Model Number: 550-683361111

Kato Type Number: 20084

Connection Size: (2) 1.25 HPP

Fuel Consumption: 40 Gal/Hr = 3,660,000 BTUH

Generator #2:

Caterpillar G399 Serial Number: 49C00644

Kato Serial Number: 86576

Kato Catalogue Code: 6P61438

Kato Model Number: 550-683361111

Kato Type Number: 21141  
Connection Size: (2) 1.25 HPP  
Fuel Consumption: 40 Gal/Hr = 3,660,000 BTUH

- (b) Total hours information is unavailable. Refer to attached photos of usage logs for 2011 to present. Generators are approximately 40 years old.
- (c) Kilowatt output for each generator is 550kW.
- (d) The existing transfer arrangement is built into the main switchgear; Transfer arrangement is not fully automatic.
- (e) Yes, the generator control panel is in working order.
- (f) No data plate photos are available. Refer to response to question (a) above.
- (g) Each generator has a ducted exhaust. A wall louver brings in outside air for cooling/makeup. VTA makes no representation as to the condition or design adequacy of the wall louver system.

Q25. We would like to request from your end that our Company, which has a C-10 and Class B Contractor License will be considered as a Prime Contractor and be considered to Bid on the said Cerone Generator Project. FYI! We are currently working on another project with SCVTA for the C18227 - Emergency Standby Generator at Eastridge Paratransit Facility. We hope that this request merits your approval.

A25. Please refer to Addendum #6.

Q26. Could you please resend the link, the link below is the home page of VTA, can't find the project documents, please help.

A26. Register as a vendor and sign up for notifications for your NAICS business codes at <https://www.vta.org/user/register?type=vendor>. Log in at <https://www.vta.org/user> or using the Vendor Login / Register button at the top of Business Center pages. View all solicitations at <https://www.vta.org/solicitations>. To download documents for a solicitation, open that solicitation and click "**Register or Log In to Download**" if you're not logged in, or "**Become a Plan Holder**" if you are. You can reset your password at <https://www.vta.org/user/password>.

If you have any questions, please do not hesitate to contact me at (408)321-5835.

Sincerely,



Ehab Azab

Construction Contracts Administrator

QUESTIONS AND ANSWERS SET # 6

CONTRACT C19010 – CERONE DIVISION EMERGENCY GENERATOR REPLACEMENT

July 25, 2019

Page 3 of 5

*[Faint handwritten notes on a separate sheet of paper, possibly a log or schedule, with some numbers and dates visible.]*

Date	Inspector's Initials	Beginning Reading	End Reading	Total Hours Operation	Remark / Reason for Use
0824	KW	799.0 1260.5	799.1 1260.6	.10	POWER OUTAGE
100211	KW	799.1 1260.6 799.25	799.25 1260.9	.2 .15	POWER OUTAGE
10/21/11	WLT MSC	1260.8	1260.9	.1	ANNUAL SERVICE
10/22/11	WLT MSC	799.4 1260.9	800.0 1261.5	.6	BUILDUP LOAD TEST
11/19/11	KW	800.0 1261.5	804.35 1265.85	4.35	SOAR TIE IN
12/14/11	KW	804.35 1265.85	804.40 1266.09	.05 .04	TEST
012212	KW	804.40 1265.89	804.44 1265.92	.05 .03	TEST
07-30-12	KP	804.44 1265.92	805.35 1266.95	.91 1.03	
8/24/12	LP	805.35 1266.95	806.25 1267.7		test
11-17-12	WME WME DME	806.7 1268.1	807.2 1268.6	.5 .5	TEST W/ TRANSFER
2-23-13	WME DME	807.2 1268.8	807.8 1269.3	.5 .5	TEST W/ TRANSFER
18 MAY 13	WME DME	808.4 1269.2	808.4 1269.9	.5 .5	Quarterly ops w/ transfer
7-2-13	KP	809.4 1269.9	809.2 1270.7	.8 .8	Power Outage
9-21-13	KP	809.2 1270.7	809.8 1271.3	.6 .6	Test w/ Transfer
12-9-13	KP	809.8 1271.3	809.9 1271.4	.01 .01	Power Outage
1-24-14	WME DME	809.9 1271.5	810.0 1271.6	.01 .01	Service & TEST RUN
24 JAN 14	WME	810.0 1271.6	810.6 1272.2	.5 .5	TEST W/ TRANSFER
2-18-14	KP	810.6 1272.2	813.1 1274.6	2.5	Power outage
18 APR 14	DME	813.1 1274.6	813.3 1275.6	.2	TEST
25 JUL 14	WME DME	813.3 1275.6	813.4 1275.7	.1 .1	Quarterly insp
08 JUL 14	DME	813.4 1275.7	813.9 1276.2	.5 .5	Qt Run 30 min
8-6-14	KP	813.9 1276.2	814.1 1276.4	.2 .2	Power Outage

*Log*

QUESTIONS AND ANSWERS SET # 6

CONTRACT C19010 – CERONE DIVISION EMERGENCY GENERATOR REPLACEMENT

July 25, 2019

Page 4 of 5

95134

ION

solvent, Burns  
Paint Booth  
Locations at: P1 Sta

th, 0 gal/yr sol  
Paint Booth  
Locations at: P2 Stack

reciprocating engin  
Paint Emergency Stan  
Locations at: P3 Stack

reciprocating engine  
Paint Emergency Stan  
Locations at: P4 Stack

HVLP Sprayer, 9.  
Paint Booth for  
Locations at: P5 Stack  
P6 Stack  
P7 Stack  
P8 Stack

ources  
Permit Condition

Street, Suite 600, San Francisco, CA 94105 - (41

9:20 P  
9:30

F.M. & EMERGENCY USE LOG

Location Cerone

Date	Inspector's Initials	Beginning Reading	End Reading	Total Hours Operation	Remark / Reason for Use
17 Oct 14	Dmc	1276.3			Replaced batteries
17 Oct 14	Dmc	814.0			Replaced batteries
18 Oct 14	Dmc	1276.3	1276.8	.5	Loaded test run
18 Oct 14	Dmc	814.0	814.5	.5	Loaded test run
12-11-14	Kp	1276.8	1277.0	.2	Power Outage
12-11-14	Kp	814.5	814.7	.2	Power Outage
#1 23-JAN-15	Dmc	814.7	814.8	.1	Changed oil
#2 23-JAN-15	Dmc	1277.0	1277.1	.1	Changed oil
24-JAN-15	OC	1277.1	1277.6	.5	Availability test
18 APR 15	BR	815.3	815.8	.5	Run w/ load
25/7/15	BR	1278.3	1279.0	.7	Run w/ load
10-1-15	Kp	816.7	817.0	.3	Power outage
10-31-15	Kp	1279.4	1279.5	.1	Run/Load Test run
1-23-16	Kp	817.2	817.3	.1	Load Test
1-23-16	BR	1279.6	1279.7	.1	Run/Load Test run
4/14/16	BR	817.3	817.3	.0	Refill Engine oil
5-16-16	KP	1280.0	1280.1	.1	load Transfer
5-23-16	DP	817.7	817.9	.2	Power outage
7-23-16	BR	1280.2	1280.7	.5	load Transfer
10/15/16	BR	817.9	818.4	.5	load Transfer
2/4/17	BR	1281.2	1281.7	.5	load Transfer
2/25/17	Kp	819.4	820.5	1.1	Power Outage

P.M. & EMERGENCY USE LOG

Location Cerone

Date	Inspector's Initials	Beginning Reading	End Reading	Total Hours Operation	Remark/ Reason for Use
6/10/17	BR	1282.8 820.5	1283.5 820.9	.5	load transfer
9-3-17	Kp	1283.3 820.9	1284.1 821.7	.8	Power outage
9-16-17	Kp	1284.1 821.7	1284.5 822.2	.5	Load Transfer Test
2-8-18	OC WMB	#1 822.2 #2 1284.5 822.3	822.3 1284.6 822.8	.1	INSPECTION / LATELY
2/10/18	BR	1284.6	1285.1	.5	load transfer test
2-23-18	Kp	823.3 1285.5	823.3 1285.6	.5	Power Outage PG&E
5-15-18	Kp	823.3 1285.6	824.1 1286.4	.8	PG&E Power Outage
5-17-18	Kp	824.1 1286.4	824.3 1286.6	.2	PG&E Power Outage
5-21-18	Kp	824.3 1286.6	824.4 1286.7	.1	PG&E Power Outage
11/17/18	BR	824.4 1286.7	825.1 1287.4	.7	load transfer test
2-18-19	Kp	825.1 1287.4	825.3 1287.6	.2	PG&E Power Outage
3-1-19	JU	1287.6 825.3	1287.6 825.3	.15 1.0	TEST RUN
3-16-19	Kp	1287.6 825.3	1288.2 826.0	.08 .07	Load Test